

CERTIFICATE

for

TÜV PROFiCERT-product Interior PREMIUM

The following product/product group particularly fulfills the criteria V2.0 of the TÜV PROFiCERT-product Interior certification. This certificate does not acquit the producer of his responsibility to comply with all legal requirements and product properties.



MEHR AUS HOLZ.


EGGER Holzwerkstoffe Wismar GmbH & Co. KG
Am Haffeld 1
23970 Wismar
Germany

Egger Hybrid flooring UC 32 and UC 33

Result of quality testing: Classification requirements according to EN 16511:2023 for the class 32 and class 33 are fulfilled

Result of the emission testing: TÜV PROFiCERT-product Interior PREMIUM fulfilled

Thus, the results comply with the emission thresholds of

√	AgBB 2024	√	BREEAM Exemplary Level	√	Austrian Ecolabel UZ 07
√		√	Finnish M1-classification (without odour / ammonia)	√	DE-UZ 176 (Blue Angel)
√	Belgian VOC-regulation	√	MVVTB Annex 8 / ABG	√	CAM Italy construction products
√	LEED v4 (outside North America)	√	QNG		

Certificate registration No. **70 720 6151-3**

Certificate valid from 2024-11-06 to **2027-11-05**

Audit report No. 2117289/2024/1

First certification 2018-11-06



Dr. M. Pawke

Darmstadt, 2024-10-30
Certification body of TÜV Hessen
– Head of Certification body –

ANNEX

This article / this group is characterized by the following features (all data $\pm 10\%$):

Utilisation class (UC):	32 and 33
Wear layer:	Polypropylene film (excimer coated) Polypropylene film UV coated (optional)
Decor layer:	Melamine resin impregnated decor-paper
Carrier layer:	HDF, thickness 5.8 mm, average density 960 kg/m ³ UC 32: recipe 623 UC 33: recipe 665 (grey coloured) and optionally recipe 663
Back layer:	Melamine resin impregnated balancer
V-joint:	4-sided
Sound insulation:	Directly laminated underlay based on recycled natural fibers Directly laminated cork underlay (optionally)
Total thickness:	7.5 mm
Area weight:	6.5 – 7.0 kg/m ²

and comprises the following articles:

EGGER AquaDura (UC 32)
EGGER AquaDura+ (UC 33)
EGGER Design Flooring Greentec (UC 33)

TÜV PROFICERT-product Interior (PREMIUM)

Certificate registration No. **70 720 6151-3**

Certificate valid from 2024-11-06 to **2027-11-05**



Dr. M. Pawke

Darmstadt, 2024-10-30
Certification body of TÜV Hessen
– Head of Certification body –